Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

TO: Franklin Twp. Elem. School - JM
P.O. Box 368
226 Quakertown Road
Quakertown NJ 08868
ATT: Patricia Martucci

REPORT # 400123099.0
CLIENT # FRA41
DATE SUBMITTED: 1/23/2020

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: FIRST DRAW - PBCU # 2
SAMPLE LOCATION: N 103 HS , 226 QUAKERTOWN RD., QUAKERTOWN, NJ 08868

Submitted via E2

DATE SAMPLED: 1/22/2020 TIME SAMPLED: 07:10

PWS ID# NJ1010300
FAC ID# TP001001

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.005	mg/l	0.015	1/29/20
Copper, EPA 200.7	0.318	mg/l	1.3	1/28/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

cc: McGowan, HCHD by email

410028

E2

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

REPORT # 400123100.0
CLIENT # FRA41
DATE SUBMITTED: 1/23/2020

TO: Franklin Twp. Elem. School - JM
P.O. Box 368
226 Quakertown Road
Quakertown NJ 08868
ATT: Patricia Martucci

Submitted via E2

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: FIRST DRAW - PBCU # 5
SAMPLE LOCATION: K FL , 226 QUAKERTOWN RD., QUAKERTOWN, NJ 08868

DATE SAMPLED: 1/22/2020 TIME SAMPLED: 07:15

PWS ID# NJ1010300
FAC ID# TP001001

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.001	mg/l	0.015	1/29/20
Copper, EPA 200.7	0.669	mg/l	1.3	1/28/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

cc: McGowan, HCHD by email

410028

E2

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercolfani, B.A., Laboratory Manager

REPORT OF ANALYSIS

REPORT # 400123101.0
CLIENT # FRA41
DATE SUBMITTED: 1/23/2020

TO: Franklin Twp. Elem. School - JM
P.O. Box 368
226 Quakertown Road
Quakertown NJ 08868
ATT: Patricia Martucci

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: FIRST DRAW - PBCU # 6
SAMPLE LOCATION: DW BY K , 226 QUAKERTOWN RD., QUAKERTOWN, NJ 08868

Submitted via E2

DATE SAMPLED: 1/22/2020 TIME SAMPLED: 07:35

PWS ID# NJ1010300
FAC ID# TP001001

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	1/29/20
Copper, EPA 200.7	0.209	mg/l	1.3	1/28/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

cc: McGowan, HCHD by email

410028

E2

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

REPORT # 400123102.0
CLIENT # FRA41
DATE SUBMITTED: 1/23/2020

TO: Franklin Twp. Elem. School - JM
P.O. Box 368
226 Quakertown Road
Quakertown NJ 08868
ATT: Patricia Martucci

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: FIRST DRAW - PBCU # 7
SAMPLE LOCATION: TL170 , 226 QUAKERTOWN RD., QUAKERTOWN, NJ 08868

Submitted via E2

DATE SAMPLED: 1/22/2020 TIME SAMPLED: 07:25

PWS ID# NJ1010300
FAC ID# TP001001

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	1/29/20
Copper, EPA 200.7	0.134	mg/l	1.3	1/28/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

cc: McGowan, HCHD by email

410028

E2

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

REPORT OF ANALYSIS

REPORT # 400123103.0
CLIENT # FRA41
DATE SUBMITTED: 1/23/2020

TO: Franklin Twp. Elem. School - JM
P.O. Box 368
226 Quakertown Road
Quakertown NJ 08868
ATT: Patricia Martucci

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: FIRST DRAW - PBCU # 8
SAMPLE LOCATION: ROOM 153 DW , 226 QUAKERTOWN RD., QUAKERTOWN, NJ 08868

Submitted via E2

DATE SAMPLED: 1/22/2020 TIME SAMPLED: 07:33

PWS ID# NJ1010300
FAC ID# TP001001

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	1/29/20
Copper, EPA 200.7	0.132	mg/l	1.3	1/28/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

cc: McGowan, HCHD by email

410028

E2

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

REPORT OF ANALYSIS

REPORT # 400123104.0
CLIENT # FRA41
DATE SUBMITTED: 1/23/2020

TO: Franklin Twp. Elem. School - JM
P.O. Box 368
226 Quakertown Road
Quakertown NJ 08868
ATT: Patricia Martucci

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: FIRST DRAW - PBCU # 9
SAMPLE LOCATION: WC110 , 226 QUAKERTOWN RD., QUAKERTOWN, NJ 08868

Submitted via E2

DATE SAMPLED: 1/22/2020 TIME SAMPLED: 07:30

PWS ID# NJ1010300
FAC ID# TP001001

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	1/29/20
Copper, EPA 200.7	0.036	mg/l	1.3	1/28/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

cc: McGowan, HCHD by email

410028

E2

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

REPORT # 400123105.0
CLIENT # FRA41
DATE SUBMITTED: 1/23/2020

TO: Franklin Twp. Elem. School - JM
P.O. Box 368
226 Quakertown Road
Quakertown NJ 08868
ATT: Patricia Martucci

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: FIRST DRAW - PBCU # 10
SAMPLE LOCATION: ROOM 148 DW , 226 QUAKERTOWN RD., QUAKERTOWN, NJ 08868

Submitted via E2

DATE SAMPLED: 1/22/2020 TIME SAMPLED: 07:31

PWS ID# NJ1010300
FAC ID# TP001001

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	1/29/20
Copper, EPA 200.7	0.178	mg/l	1.3	1/28/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

cc: McGowan, HCHD by email

410028

E2

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

REPORT # 400123106.0
CLIENT # FRA41
DATE SUBMITTED: 1/23/2020

TO: Franklin Twp. Elem. School - JM
P.O. Box 368
226 Quakertown Road
Quakertown NJ 08868
ATT: Patricia Martucci

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: FIRST DRAW - PBCU # 11
SAMPLE LOCATION: K FR , 226 QUAKERTOWN RD., QUAKERTOWN, NJ 08868

Submitted via E2

DATE SAMPLED: 1/22/2020 TIME SAMPLED: 07:17

PWS ID# NJ1010300
FAC ID# TP001001

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	1/29/20
Copper, EPA 200.7	0.197	mg/l	1.3	1/28/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

cc: McGowan, HCHD by email

410028

E2

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

REPORT # 400123107.0
CLIENT # FRA41
DATE SUBMITTED: 1/23/2020

TO: Franklin Twp. Elem. School - JM
P.O. Box 368
226 Quakertown Road
Quakertown NJ 08868
ATT: Patricia Martucci

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: FIRST DRAW - PBCU # 12
SAMPLE LOCATION: ROOM 149 DW , 226 QUAKERTOWN RD., QUAKERTOWN, NJ 08868

Submitted via E2

DATE SAMPLED: 1/22/2020 TIME SAMPLED: 07:32

PWS ID# NJ1010300
FAC ID# TP001001

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	1/29/20
Copper, EPA 200.7	0.158	mg/l	1.3	1/28/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

cc: McGowan, HCHD by email

410028

E2

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

REPORT # 400123108.0
CLIENT # FRA41
DATE SUBMITTED: 1/23/2020

TO: Franklin Twp. Elem. School - JM
P.O. Box 368
226 Quakertown Road
Quakertown NJ 08868
ATT: Patricia Martucci

Submitted via E2

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: FIRST DRAW - PBCU # 13
SAMPLE LOCATION: TL141 , 226 QUAKERTOWN RD., QUAKERTOWN, NJ 08868

DATE SAMPLED: 1/22/2020 TIME SAMPLED: 07:12

PWS ID# NJ1010300
FAC ID# TP001001

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	1/29/20
Copper, EPA 200.7	0.211	mg/l	1.3	1/28/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

cc: McGowan, HCHD by email

410028

E2

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.