



Annual Drinking Water Quality Report
Franklin Township Elementary School
PWSID# NJ1010300
For the Year 2024, Results from the Year 2023

Franklin Township Elementary School is pleased to present to you this year's Annual Drinking Water Quality Report. Our drinking water is pumped from 1 active well on site in Hunterdon County.

Landlords must distribute this information to every tenant as soon as practicable, but no later than three business days after receipt. Delivery must be done by hand, mail, or email, and by posting the information in a prominent location at the entrance of each rental premises, pursuant to section 3 of P.L. 2021, c. 82 (C.58:12A-12.4 et seq.).

Franklin Township Elementary School routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the test results of our monitoring for the period of January 1st to December 31st, 2023. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our test results, though representative, are more than one year old and are the most recent results available.

Vulnerable Populations: Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

| TABLE OF DETECTED CONTAMINANTS | | | | | | |
|---|---------------|--|----------------------|-------|--------|---|
| Contaminant | Violation Y/N | Level Detected | Units of Measurement | MC LG | MCL | Likely Source of Contamination |
| Inorganic Contaminants | | | | | | |
| Barium Test Results Yr.: 2022 | N | 0.138 | ppm | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| Copper Result at 90th Percentile | N | 0.343 0.5 No samples exceeded AL | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits |
| Fluoride Test Results Yr.: 2022 | N | 0.065 | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| Lead Result at 90th Percentile | N | ND 1.41 No samples exceeded AL | ppb | 0 | AL=15 | Corrosion of household plumbing systems, erosion of natural deposits |
| Nickel Test Results Yr.: 2022 | N | 1.83 | ppb | n/a | n/a | Erosion of natural deposits |
| Nitrate | N | 2.83 | ppm | 10 | 10 | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
| PFAS Per- and Polyfluoroalkyl Substances | | | | | | |
| PFOS Perfluorooctane Sulfonic Acid | N | Range: 4.2 to 4.4 Highest Avg: 4.3 | ppt | n/a | 13 | Discharge from industrial, chemical factories, release of aqueous film forming foam. |
| PFOA Perfluorooctanoic Acid | N | Range: 5.3 to 6.3 Highest Avg: 5.8 | ppt | n/a | 14 | Discharge from industrial, chemical, and manufacturing factories, release of aqueous film forming foam. |
| Disinfection By-products | | | | | | |
| HAA5 Haloacetic Acids | N | 1.02 | ppb | n/a | 60 | By-product of drinking water disinfection |
| TTHM Total Trihalomethanes | N | 5.1 | ppb | n/a | 80 | By-product of drinking water disinfection |

| TABLE OF DETECTED CONTAMINANTS | | | | | | |
|---|----------------|------------------------------|-----------------------|-------|-----|--------------------------------|
| Contaminant | Violati on Y/N | Level Detected | Units of Measure ment | MC LG | MCL | Likely Source of Contamination |
| Radioactive Contaminants | | | | | | |
| Alpha emitters Test results Yr.: 2019 | N | Range: ND to 4.3 Avg: 2.7 | pCi/1 | 0 | 15 | Erosion of natural deposits |
| Combined radium Test results Yr.: 2019 | N | Range: ND to 3 Avg: 1.125 | pCi/1 | 0 | 5 | Erosion of natural deposits |

| Regulated Disinfectants | Violati on Y/N | Level Detected (Average, Lowest & Highest Detect) | Units of Measure ment | MRDL | MRDLG | Typical Source |
|-------------------------|----------------|---|-----------------------|------|-------|---|
| Chlorine | N | Average = 0.96 Lowest = 0.00 Highest = 1.54 | ppm | 4.0 | 4.0 | Water additive used to control microbes |

Potential Sources of Contamination: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Franklin Township Elementary School is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

DEFINITIONS

In the "TABLE OF DETECTED CONTAMINANTS" you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000

Picocuries per liter (pCi/L) - Picocuries per liter is a measure of the radioactivity in water.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal -The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Secondary Contaminant - Substances that do not have an impact on health. Secondary Contaminants affect aesthetic qualities such as odor, taste or appearance. Secondary standards are recommendations, not mandates.

Recommended Upper Limit (RUL) – Recommended maximum concentration of secondary contaminants. These reflect aesthetic qualities such as odor, taste or appearance. RULs are recommendations, not mandates.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Goal (MRDLG): The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination

Waivers: The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, volatile organic chemicals and synthetic organic chemicals. Our system received a monitoring waiver for asbestos and received a waiver for synthetic organic chemicals (SOC) for the previous waiver period. We have applied for and expect to receive a SOC waiver for the current waiver period upon NJDEP approval.

For Additional Information: If you have any questions about this report or concerning your water quality, please contact Franklin Township Elementary School at (908)735-7929 or attend one of our regular Board of Education meetings at 6:30 pm on the dates posted on our website, www.ftschoo.org. We want our valued customers to be informed about their water quality.

Source Water Assessment: The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for this public water system, which is available at <http://www.nj.gov/dep/watersupply/swap/index.html>, or by contacting the NJDEP, Bureau of Safe Drinking Water at 609-292-5550 or watersupply@dep.nj.gov.

Susceptibility Ratings for Franklin Township Elementary School Sources

The table below illustrates the susceptibility ratings for the seven contaminant categories (and radon) for each source in the system. The table provides the number of wells and intakes that rated high (H), medium (M), or low (L) for each contaminant category. For susceptibility ratings of purchased water, refer to the specific water system’s source water assessment report.

The seven contaminant categories are defined at the bottom of this page. DEP considered all surface water highly susceptible to pathogens, therefore all intakes received a high rating for the pathogen category. For the purpose of Source Water Assessment Program, radionuclides are more of a concern for ground water than surface water. As a result, surface water intakes’ susceptibility to radionuclides was not determined and they all received a low rating.

If a system is rated highly susceptible for a contaminant category, it does not mean a customer is or will be consuming contaminated drinking water. The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, DEP may customize (change existing) monitoring schedules based on the susceptibility ratings.

| Sources | Pathogens | | | Nutrients | | | Pesticides | | | Volatile Organic Compounds | | | Inorganics | | | Radio-nuclides | | | Radon | | | Disinfection Byproduct Precursors | | | |
|-----------|-----------|---|---|-----------|---|---|------------|---|---|----------------------------|---|---|------------|---|---|----------------|---|---|-------|---|---|-----------------------------------|---|---|--|
| | H | M | L | H | M | L | H | M | L | H | M | L | H | M | L | H | M | L | H | M | L | H | M | L | |
| Wells - 1 | | | 1 | | 1 | | | 1 | | | | 1 | 1 | | | 1 | | | 1 | | | | 1 | | |

Pathogens: Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.

Nutrients: Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

Volatile Organic Compounds: Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

Pesticides: Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

Inorganics: Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.

Radionuclides: Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.

Radon: Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to <http://www.nj.gov/dep/rpp/radon/index.htm> or call (800) 648-0394.

Disinfection Byproduct Precursors: A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.